



Garden State Laboratories, Inc.

Report Date: 05/28/2021

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Urban League of Essex County
508 Central Ave

Newark, NJ 07107

Attention: Heather Wilson

Client Number: URB01

Laboratory Director:

Sample ID: Lab Sample ID: 210517024-01
Site: Classroom 2 Collection Date/Time: 05/17/2021 07:45
Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.126 mg/l	1.3	0.0100	0.0021	20044	05/25/21 09:38	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/25/21 11:56	

Sample ID: Lab Sample ID: 210517024-02
Site: Kitchen 504 Collection Date/Time: 05/17/2021 07:45
Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.181 mg/l	1.3	0.0100	0.0021	20044	05/25/21 09:42	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/25/21 11:59	

Sample ID: Lab Sample ID: 210517024-03
Site: Ladies Rm 504 Collection Date/Time: 05/17/2021 07:45
Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0907 mg/l	1.3	0.0100	0.0021	20044	05/25/21 09:47	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/25/21 12:02	



Sample ID: Lab Sample ID: 210517024-04
 Site: Mens Rm 504 Collection Date/Time: 05/17/2021 07:45
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.156 mg/l	1.3	0.0100	0.0021	20044	05/25/21 09:51	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/25/21 12:05	

Sample ID: Lab Sample ID: 210517024-05
 Site: Classroom 1 Collection Date/Time: 05/17/2021 07:45
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0623 mg/l	1.3	0.0100	0.0021	20044	05/25/21 09:56	
Lead, Total Recoverable	EPA 200.9	1	0.00124 mg/l	0.015	0.00100	0.00055	20044	05/25/21 12:08	

Sample ID: Lab Sample ID: 210517024-06
 Site: Classroom 4 Collection Date/Time: 05/17/2021 07:45
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.103 mg/l	1.3	0.0100	0.0021	20044	05/25/21 10:00	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/25/21 12:10	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
 The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

